

Office Of the Public Analyst, Public Health Laboratory, Jammu

No:-FSSA/J/

2138

Dated :-

18-1-19

Subject:- Analytical report of the sample of Water .

The analytical report of the sample of Water received from MAHARAJA HARISINGH AGRICULTURAL COLLEGIATE SCHOOL NAGBANI, JAMMU on 10/1/19 vide letter No: MHAC/F.95/1046 Dated 7/1/19 is asunder:-

Analysis Report:-


Sample Description:- The sample was received in Plastic Bottle..

Physical Appearance:- colourless & free from impurities.

Label:- Nil.

S.NO.	Quality Characteristics	Name of the Method of test used	Results
1.	Suspended Impurities	Physical Appearance	Absent.
2.	Total Dissolved solids	Gravimetric Method	520mg/Litre
3.	Residual free Chlorine	Chemical method	Absent
4.	Alkalinity (as Hco3)	-----DO-----	186mg/Litre
5.	PH	PH Meter	7.2
6.	Turbidity	Turbidity Meter	1NTU
7.	Chloride	Chemical Method	23.04mg/ltr.

Opinion:- The water is suitable for drinking purpose.


FOOD ANALYST
JAMMU PROVINCE

Address:

MAHARAJA HARISINGH
AGRICULTURAL COLLEGIATE SCHOOL
NAGBANI, JAMMU

Copy to the:- Commissioner of Food safety, J&K, Jammu.


OFFICE OF THE BLOCK MEDICAL OFFICER PHC KOT-BHALWAL

HEALTH & SANITARY/SANITATION CERTIFICATE.

In reference to MHACS/F-95/940 dated:- 18-12-2018 of "MAHARAJAHARI SINGH AGRICULTURAL COLLEGATE SCHOOL, NAGBANI JAMMU, have submitted application for health & sanitary/sanitation Certificate in the office of the U/S. The Block Medical officer has constituted a team to see the factual position regarding Sanitation; they have submitted a report that Sanitary/Sanitation is satisfactory. Hence the sanitary/sanitation Certificate issued by the Block Medical Officer, PHC Kot-Bhalwal in favour of the School.

No:-BMO/KB/Estt/ 2036

Dated:- 19-1-2019


Block Medical Officer
(DR. MANZOOR HUSSAIN)
P.H.C. Kot Bhalwal
Health and Family Welfare
Jammu.

Copy to the:-

1. The Principal MHACS, Nagbani, Jammu for information.
2. Office File.